


**DIMENSIONS IN
INCHES**



COMPONENT IDENTIFICATION
REFLECTED ON BILL OF MATERIALS
DRAWING # 204

	Future Breaker	Future Breaker	Future Breaker
P	P	P	P
D	D	D	D
B	B	B	B
"A"	"B"	"C"	

NOTE 1:
MOTOR CONTROL WIRING
LIMITED TO A MAXIMUM OF:
15 HP @ 230 VOLTS
25 HP @ 460 VOLTS

SCALE:	N.T.S.	-	REVISIONS AS PER MEETING	09-04-2013	JG
DESIGN:	JAG /LS	1	ADDED R1 AND R2	06-06-2014	JG
DRAWN BY:	JG	2	REVISED LOCATION ID 21	06-23-2014	JG
APPROVED BY:	WW	NO	REVISION	DATE	BY



WASTEWATER DIVISION,
INDUSTRIAL AUTOMATION GROUP

CITY OF
 ORLANDO, FLORIDA

TITLE:

LIFT STATIONS STANDARDS
< 25 HP NEMA STARTER
DUPLEX PCP FOR STATIONERY GENERATOR
INTERIOR LAYOUT

SHEET
203B