



SCALE: N.T.S.		1	ADDED FTB DRAWING NOTES AND LAYER		JG
DESIGN: IAG / JS		2	ADDED TD-3 TRIGGER AND CONTACT		JG
DRAWN BY: JG		3	REVISED BFR WIRING TO VFD FIXED SET POINT INPUT		JG
APPROVED BY: WW		4	ADDED R5 AND WIRING		JG
		5	REVISED DIN "3" TYPE		JG
		NO	REVISION		DATE
					BY
WASTEWATER DIVISION, INDUSTRIAL AUTOMATION GROUP		TITLE:		LIFT STATIONS STANDARDS ≥ 50 HP VFD WITH SSRVS PUMP CONTROLLER CONTROL WIRING SCHEMATIC PART 2	
CITY OF ORLANDO, FLORIDA				SHEET 408	