



NOTE 1:  
MOTOR CONTROL WIRING  
LIMITED TO A MAXIMUM OF:  
20 HP @ 230 VOLTS  
50 HP @ 460 VOLTS

COMPONENT IDENTIFICATION  
REFLECTED ON BILL OF MATERIALS  
DRAWING # 504

|   |          |                             |   |   |    |               |  |
|---|----------|-----------------------------|---|---|----|---------------|--|
| SCALE: N.T.S.                                       |          | REVISIONS AS PER MEETINGS   |   | DATE  |    | BY            |  |
| DESIGN:   | IAG / LS | 1                           | ADDED ITEM 42                             | 06-26-2014  | JG |               |  |
| DRAWN BY:   | JG       | 2                           | REVISED INTERLOCK AND REMOVE CB SLIDE BAR | 04-10-2015  | JG |               |  |
| APPROVED BY:  | GM       |                             |   |   |    |               |  |
| WASTEWATER DIVISION,<br>INDUSTRIAL AUTOMATION GROUP |          | CITY OF<br>ORLANDO, FLORIDA |   | LIFT STATIONS STANDARDS<br>25 HP TO < 50 HP<br>TRIPLEX SSRVS PUMP CONTROLLER FOR<br>PORTABLE GENERATOR<br>INTERIOR LAYOUT |    | SHEET<br>513A |  |